

APPENDIX W

NYS Energy Conservation REScheck
Compliance Certificate

 Permit Number

 Checked By/Date

REScheck Compliance Certificate**New York State Energy Conservation Construction Code**

REScheck Software Version 3.5 Release 1a

Data filename: Z:\JOBS\JOSE\REScheck\LIEBOWITZ- 0907.rck

TITLE: PROPOSED RESIDENCES

COUNTY: Rockland
 STATE: New York
 HDD: 4910
 CONSTRUCTION TYPE: Multifamily
 HEATING TYPE: Non-Electric

DATE: 04/03/09
 DATE OF PLANS: 02-25-09

PROJECT INFORMATION:
 MR. LIEBOWITZ
 ROUTE 202
 RAMAPO, N.Y.

COMPANY INFORMATION:
 HY GARFINKEL AIA
 MONSEY, N.Y.
 (845) 356-7777

COMPLIANCE: Passes

Maximum UA = 2548
 Your Home UA = 1374
 46.1% Better Than Code (UA)

	<u>Gross Area or Perimeter</u>	<u>Cavity R-Value</u>	<u>Cont. R-Value</u>	<u>Glazing or Door U-Factor</u>	<u>UA</u>
Ceiling: Flat Ceiling or Scissor Truss	6407	39.0	0.0		192
Wall 3: Wood Frame, 16" o.c.	2992	21.0	3.0		121
Window: Wood Frame:Double Pane	626			0.300	188
Wall 2: Wood Frame, 16" o.c.	3366	21.0	3.0		132
Window: Wood Frame:Double Pane	541			0.300	162
Door: Glass	240			0.300	72
Wall 1: Wood Frame, 16" o.c.	3115	21.0	3.0		126
Window: Wood Frame:Double Pane	530			0.300	159
Door: Solid	120			0.140	17
Floor: All-Wood Joist/Truss:Over Unconditioned Space	6210	30.0	0.0		205
Furnace 1: Forced Hot Air, 78 AFUE					

COMPLIANCE STATEMENT: The proposed building represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed systems have been designed to meet the New York State Energy Conservation Construction Code requirements. When a Registered Design Professional has stamped and

signed this page, they are attesting that to the best of his/her knowledge, belief, and professional judgment, such plans or specifications are in compliance with this Code.

Builder/Designer *H. Garfinkel*

Date 4/3/09